



at the RM. Kirby Center

705 Central Avenue • New Providence, New Jersey 07974 • Phone (908) 508-0011 Fax (908) 508-0012

May 2017


Dear Parents/Guardians:

Summit Speech School arranged to test the water for lead in the school. Every faucet and water cooler throughout the school was tested.

**No sampled water source exceeds the Environmental Protection Agency (EPA) recommended maximum lead content level in drinking water for schools and child care centers of 15 parts per billion (ppb); see results attached below.**

Summit Speech School takes children's' safety very seriously, and, as such, will continue to take a proactive approach in protecting our children and our community by testing the water every few years.

Summit Speech School Administration



# Garden State Laboratories, Inc.

Bacteriological and Chemical Testing

410 Hillside Avenue  
 Hillside, New Jersey 07205

Mathew Klein, M.S., Founder (1916-1996)  
 Harvey Klein, M.S., Laboratory Director



Toll Free 800-273-8901  
 Telephone 908-688-8900  
 Fax 908-688-8966  
 email: info@gsllabs.com  
 Internet: www.gsllabs.com

**REPORT OF ANALYSIS**

TO: Summit Speech School  
 705 Central Avenue

REPORT # 370516031.0  
 CLIENT # SUM24  
 DATE SUBMITTED: 5/16/2017

New Providence NJ 07974  
 ATT: Pamela Ranco

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: 71110151

SAMPLE LOCATION: THERAPY 1,705 CENTRAL AVE., NEW PROVIDENCE, NJ 07974

DATE SAMPLED: 5/16/2017

TIME SAMPLED: 07:16

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	1.5	ug/l	15	5/18/17-12:39
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)	No			

< = less than, not detected. Method Detection Limits and Reporting Limits available at [www.gsllabs.com/certnjdep.html](http://www.gsllabs.com/certnjdep.html)  
 MCL = Maximum Contaminant Level allowed by State and Federal regulations.

*Harvey Klein*

308055

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.  
 Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.



# Garden State Laboratories, Inc.

Bacteriological and Chemical Testing

410 Hillside Avenue  
Hillside, New Jersey 07205

Mathew Klein, M.S., Founder (1916-1996)  
Harvey Klein, M.S., Laboratory Director



Toll Free 800-273-8901  
Telephone 908-688-8900  
Fax 908-688-8966  
email: info@gsllabs.com  
Internet: www.gsllabs.com

**REPORT OF ANALYSIS**

TO: Summit Speech School  
705 Central Avenue

REPORT # 370516032.0

CLIENT # SUM24

DATE SUBMITTED: 5/16/2017

New Providence

NJ 07974

ATT: Pamela Ranco

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: 81110148

SAMPLE LOCATION: THERAPY 2,705 CENTRAL AVE., NEW PROVIDENCE, NJ 07974

DATE SAMPLED: 5/16/2017


TIME SAMPLED: 07:14

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	1.5	ug/l	15	5/18/17-12:42
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)	No			

< = less than, not detected. Method Detection Limits and Reporting Limits available at [www.gsllabs.com/certnjdep.html](http://www.gsllabs.com/certnjdep.html)  
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

308055

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.  
Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.



# Garden State Laboratories, Inc.

*Bacteriological and Chemical Testing*

410 Hillside Avenue  
Hillside, New Jersey 07205



Toll Free 800-273-8901  
Telephone 908-688-8900  
Fax 908-688-8966  
email: info@gsllabs.com  
Internet: www.gsllabs.com

Mathew Klein, M.S., Founder (1916-1996)  
Harvey Klein, M.S., Laboratory Director

## REPORT OF ANALYSIS

TO: Summit Speech School  
705 Central Avenue

New Providence  
ATT: Pamela Ranco

NJ 07974

REPORT # 370516033.0  
CLIENT # SUM24  
DATE SUBMITTED: 5/16/2017

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: 91110141

SAMPLE LOCATION: DISCOVERY, 705 CENTRAL AVE., NEW PROVIDENCE, NJ 07974

DATE SAMPLED: 5/16/2017


TIME SAMPLED: 07:11

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	<1.0	ug/l	15	5/18/17-12:45

< = less than, not detected. Method Detection Limits and Reporting Limits available at [www.gsllabs.com/certnjdep.html](http://www.gsllabs.com/certnjdep.html)  
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

308055

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.  
Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.



Mathew Klein, M.S., Founder (1916-1996)  
Harvey Klein, M.S., Laboratory Director

# Garden State Laboratories, Inc.

Bacteriological and Chemical Testing

410 Hillside Avenue  
Hillside, New Jersey 07205



Toll Free 800-273-8901  
Telephone 908-688-8900  
Fax 908-688-8966  
email: [info@gslabs.com](mailto:info@gslabs.com)  
Internet: [www.gslabs.com](http://www.gslabs.com)

## REPORT OF ANALYSIS

TO: Summit Speech School  
705 Central Avenue

New Providence NJ 07974  
ATT: Pamela Ranco

REPORT # 370516034.0

CLIENT # SUM24

DATE SUBMITTED: 5/16/2017

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: 101110136

SAMPLE LOCATION: PSH 1,705 CENTRAL AVE., NEW PROVIDENCE, NJ 07974

DATE SAMPLED: 5/16/2017

TIME SAMPLED: 07:10

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	1.6	ug/l	15	5/18/17-12:48
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)	No			

< = less than, not detected. Method Detection Limits and Reporting Limits available at [www.gslabs.com/certnjddep.html](http://www.gslabs.com/certnjddep.html)

MCL = Maximum Contaminant Level allowed by State and Federal regulations.

*Harvey Klein*

308055

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.  
Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.



# Garden State Laboratories, Inc.

Bacteriological and Chemical Testing

410 Hillside Avenue  
Hillside, New Jersey 07205

Mathew Klein, M.S., Founder (1916-1996)  
Harvey Klein, M.S., Laboratory Director



Toll Free 800-273-8901  
Telephone 908-688-8900  
Fax 908-688-8966  
email: info@gsllabs.com  
Internet: www.gsllabs.com

## REPORT OF ANALYSIS

TO: Summit Speech School  
705 Central Avenue

New Providence  
ATT: Pamela Ranco

NJ 07974

REPORT # 370516035.0  
CLIENT # SUM24  
DATE SUBMITTED: 5/16/2017

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: 111110131

SAMPLE LOCATION: PSH 2,705 CENTRAL AVE., NEW PROVIDENCE, NJ 07974

DATE SAMPLED: 5/16/2017

TIME SAMPLED: 07:08

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	4.0	ug/l	15	5/18/17-12:51
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)	No			

< = less than, not detected. Method Detection Limits and Reporting Limits available at [www.gsllabs.com/certnjdep.html](http://www.gsllabs.com/certnjdep.html)

MCL = Maximum Contaminant Level allowed by State and Federal regulations.

*Harvey Klein*

308055

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.  
Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.



# Garden State Laboratories, Inc.

*Bacteriological and Chemical Testing*

410 Hillside Avenue  
Hillside, New Jersey 07205

Mathew Klein, M.S., Founder (1916-1996)  
Harvey Klein, M.S., Laboratory Director



Toll Free 800-273-8901  
Telephone 908-688-8900  
Fax 908-688-8966  
email: info@gslabs.com  
Internet: www.gslabs.com

## REPORT OF ANALYSIS

TO: Summit Speech School  
705 Central Avenue

REPORT # 370516036.0

CLIENT # SUM24

DATE SUBMITTED: 5/16/2017

New Providence

NJ 07974

ATT: Pamela Ranco

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: 11630121

SAMPLE LOCATION: STAFF LOUNGE, 705 CENTRAL AVE., NEW PROVIDENCE, NJ  
07974

DATE SAMPLED: 5/16/2017

TIME SAMPLED: 07:24

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	<1.0	ug/l	15	5/18/17-12:53
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)	No			

< = less than, not detected. Method Detection Limits and Reporting Limits available at [www.gslabs.com/certnjdep.html](http://www.gslabs.com/certnjdep.html)  
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

308055

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.  
Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.



# Garden State Laboratories, Inc.

Bacteriological and Chemical Testing

410 Hillside Avenue  
Hillside, New Jersey 07205

Mathew Klein, M.S., Founder (1916-1996)  
Harvey Klein, M.S., Laboratory Director



Toll Free 800-273-8901  
Telephone 908-688-8900  
Fax 908-688-8966  
email: info@gsllabs.com  
Internet: www.gsllabs.com

## REPORT OF ANALYSIS

TO: Summit Speech School  
705 Central Avenue

REPORT # 370516037.0  
CLIENT # SUM24  
DATE SUBMITTED: 5/16/2017

New Providence  
ATT: Pamela Ranco

NJ 07974

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: 31350114

SAMPLE LOCATION: BOARD CONFERENCE ROOM, 705 CENTRAL AVE., NEW  
PROVIDENCE, NJ 07974

DATE SAMPLED: 5/16/2017

TIME SAMPLED: 07:21

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	<1.0	ug/l	15	5/18/17-12:58
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)	No			

< = less than, not detected. Method Detection Limits and Reporting Limits available at [www.gsllabs.com/certnjd.html](http://www.gsllabs.com/certnjd.html)  
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

308055

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.  
Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.





# Garden State Laboratories, Inc.

*Bacteriological and Chemical Testing*

410 Hillside Avenue  
Hillside, New Jersey 07205

Mathew Klein, M.S., Founder (1916-1996)  
Harvey Klein, M.S., Laboratory Director



Toll Free 800-273-8901  
Telephone 908-688-8900  
Fax 908-688-8966  
email: info@gsllabs.com  
Internet: www.gsllabs.com

**REPORT OF ANALYSIS**

TO: Summit Speech School  
705 Central Avenue

REPORT # 370516038.0  
CLIENT # SUM24  
DATE SUBMITTED: 5/16/2017

New Providence NJ 07974  
ATT: Pamela Ranco

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: 41540106

SAMPLE LOCATION: NURSE'S OFFICE, 705 CENTRAL AVE., NEW PROVIDENCE, NJ  
07974

DATE SAMPLED: 5/16/2017

TIME SAMPLED: 07:20

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	<1.0	ug/l	15	5/18/17-12:59
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)	No			

< = less than, not detected. Method Detection Limits and Reporting Limits available at [www.gsllabs.com/certnjdep.html](http://www.gsllabs.com/certnjdep.html)  
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

*Harvey Klein*  
308055

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.  
Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.





# Garden State Laboratories, Inc.

Bacteriological and Chemical Testing

410 Hillside Avenue  
Hillside, New Jersey 07205

Mathew Klein, M.S., Founder (1916-1996)  
Harvey Klein, M.S., Laboratory Director



Toll Free 800-273-8901  
Telephone 908-688-8900  
Fax 908-688-8966  
email: info@gsllabs.com  
Internet: www.gsllabs.com

## REPORT OF ANALYSIS

TO: Summit Speech School  
705 Central Avenue

New Providence  
ATT: Pamela Ranco

NJ 07974

REPORT # 370516040.0

CLIENT # SUM24

DATE SUBMITTED: 5/16/2017

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: 61635154

SAMPLE LOCATION: KITCHEN, 705 CENTRAL AVE., NEW PROVIDENCE, NJ 07974

DATE SAMPLED: 5/16/2017

TIME SAMPLED: 07:17

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead	<1.0	ug/l	15	5/18/17-13:05
Analytical Method	EPA 200.9			
Reporting Limit, ug/l	1.0			
Dilution Factor	None			
Digested (Y/N)	No			

< = less than, not detected. Method Detection Limits and Reporting Limits available at [www.gsllabs.com/certnjdep.html](http://www.gsllabs.com/certnjdep.html)  
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

308055

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.  
Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.



