



SUMMIT SPEECH SCHOOL

705 Central Avenue; Suite 1
New Providence, New Jersey 07974
phone (908) 508-0011 fax (908) 508-0012
www.summitspeech.org

June 15, 2022


Dear Parents/Guardians:

Summit Speech School arranged to test the water for lead in the school. Every faucet and water cooler throughout the school was tested.

No sampled water source exceeds the Environmental Protection Agency recommended maximum lead content level in drinking water for schools and child-care centers of 15 parts per billion (ppb); see results attached below.

Summit Speech School takes children's safety very seriously, and, as such, will continue to take a proactive approach to protecting our children and our community by testing the water every few years.

Summit Speech School Administration



Garden State Laboratories, Inc.

Report Date: 06/14/2022

Bacteriological and Chemical Testing

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
Email: info@gslabs.com
Internet: www.gslabs.com

Main Lab
410 Hillside Avenue
Hillside, New Jersey 07205
NJDEP Lab Cert. #20044

Jersey Shore Lab
54 Main Street
Waretown, New Jersey 08758
NJDEP Lab Cert. #15037

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director
Jordan B. Klein, B.A., Exec. Vice President
Sharon Ercoliani, B.A. Laboratory Manager

For: Summit Speech School
705 Central Ave.

New Providence, NJ 07974

Laboratory Director:

Attention: Pamela Ranco

Client Number: SUM24

Sample ID: Summit Speech School-705
Central Avenue, New
Providence, NJ 07974/Field
Blank

Lab Sample ID: 220608098-01

Site: Collection Date/Time: 06/06/2022 06:10

Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.8	1	< 0.00100 mg/l	0.015	0.00100	6E-05	20044	06/14/22 10:29	

Sample ID: Summit Speech School-705
Central Avenue, New
Providence, NJ 07974/Office
Sink

Lab Sample ID: 220608098-02

Site: Collection Date/Time: 06/06/2022 06:10

Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.8	1	< 0.00100 mg/l	0.015	0.00100	6E-05	20044	06/14/22 10:33	

Sample ID: Summit Speech School-705
Central Avenue, New
Providence, NJ 07974/Office
Water Cooler

Lab Sample ID: 220608098-03

Site: Collection Date/Time: 06/06/2022 06:11

Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.8	1	< 0.00100 mg/l	0.015	0.00100	6E-05	20044	06/14/22 10:37	



Sample ID: Summit Speech School-705 Lab Sample ID: 220608098-04
 Central Avenue, New
 Providence, NJ
 07974/Bathroom Sink
 Womens

Site: Collection Date/Time: 06/06/2022 06:15

Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.8	1	< 0.00100 mg/l	0.015	0.00100	6E-05	20044	06/14/22 10:56	

Sample ID: Summit Speech School-705 Lab Sample ID: 220608098-05
 Central Avenue, New
 Providence, NJ 07974/Staff
 Kitchen

Site: Collection Date/Time: 06/06/2022 06:17

Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.8	1	< 0.00100 mg/l	0.015	0.00100	6E-05	20044	06/14/22 10:59	

Sample ID: Summit Speech School-705 Lab Sample ID: 220608098-06
 Central Avenue, New
 Providence, NJ 07974/Nurse
 Sink

Site: Collection Date/Time: 06/06/2022 06:21

Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.8	1	0.00286 mg/l	0.015	0.00100	6E-05	20044	06/14/22 11:11	

Sample ID: Summit Speech School-705 Lab Sample ID: 220608098-07
 Central Avenue, New
 Providence, NJ 07974/Kids
 Kitchen

Site: Collection Date/Time: 06/06/2022 06:22

Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.8	1	< 0.00100 mg/l	0.015	0.00100	6E-05	20044	06/14/22 11:14	



Sample ID: Summit Speech School-705 Lab Sample ID: 220608098-08
 Central Avenue, New
 Providence, NJ 07974/Class
 Rm 136

Site: Collection Date/Time: 06/06/2022 06:26

Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.8	1	< 0.00100 mg/l	0.015	0.00100	6E-05	20044	06/14/22 11:18	

Sample ID: Summit Speech School-705 Lab Sample ID: 220608098-09
 Central Avenue, New
 Providence, NJ 07974/Class
 Rm 141

Site: Collection Date/Time: 06/06/2022 06:25

Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.8	1	< 0.00100 mg/l	0.015	0.00100	6E-05	20044	06/14/22 11:22	

Sample ID: Summit Speech School-705 Lab Sample ID: 220608098-10
 Central Avenue, New
 Providence, NJ 07974/Class
 Rm 131

Site: Collection Date/Time: 06/06/2022 06:27

Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.8	1	< 0.00100 mg/l	0.015	0.00100	6E-05	20044	06/14/22 11:26	

Sample ID: Summit Speech School-705 Lab Sample ID: 220608098-11
 Central Avenue, New
 Providence, NJ 07974/Class
 Rm 128

Site: Collection Date/Time: 06/06/2022 06:29

Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.8	1	< 0.00100 mg/l	0.015	0.00100	6E-05	20044	06/14/22 11:29	



Sample ID: Summit Speech School-705 Lab Sample ID: 220608098-12
 Central Avenue, New
 Providence, NJ 07974/Water
 Cooler follow up

Site: Collection Date/Time: 06/06/2022 06:45

Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.8	1	< 0.00100 mg/l	0.015	0.00100	6E-05	20044	06/14/22 11:41	

*DF=Dilution factor; <=less than, MCL=Maximum Contaminant Level, Rep. Limit=Reporting Limit and MDL=Method Detection Limit.
 The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
 When sample is collected by Garden State Labs, it is taken in accordance with the most current Field Sampling Plan GSL.FS.
 Main Lab certified by NJDEP #20044-TNI, NY Dept. of Health #11550 and PADEP #68-03680.*



Garden State Laboratories, Inc.