



SUMMIT SPEECH SCHOOL

705 Central Avenue; Suite 1
New Providence, New Jersey 07974
phone (908) 508-0011 fax (908) 508-0012
www.summitspeech.org

April 2025


Dear Parents/Guardians:

Summit Speech School arranged to test the drinking water for lead in the school as required by the Department of Education.

No sampled water source exceeds the Environmental Protection Agency recommended maximum lead content level in drinking water for schools and childcare centers of 15 parts per billion (ppb); see results attached below.

Summit Speech School takes children's safety very seriously, and, as such, will continue to take a proactive approach to protecting our children and our community by testing the water every few years.

Summit Speech School Administration



Garden State Laboratories, Inc.

Report of Analysis

410 Hillside Ave.
Hillside, NJ 07205

Telephone: 800-273-8901
Email: info@gslabs.com
Internet: www.gslabs.com

Main Lab
NJDEP Lab Cert. #20044

Jersey Shore Lab
NJDEP Lab Cert. #15037

Lakehurst Lab
NJDEP Lab Cert. #15041

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director
Jordan B. Klein, B.A., Exec. Vice President
Sharon Ercoliani, B.A. Manager Emerita

For: Summit Speech School
705 Central Ave.

New Providence, NJ 07974

Laboratory Director:

Report Date: 04/21/2025

Attention: Pamela Volpe

Client Number: SUM24

Sample ID: Summit Speech School - 705
Central Avenue. Mew
Providence NJ 07974 /Field
Blank

Lab Sample ID: 250409017-01

Site: Collection Date/Time: 04/08/2025 05:29

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	04/13/25 19:44	

Sample ID: Summit Speech School - 705
Central Avenue. Mew
Providence NJ 07974 /RM 141

Lab Sample ID: 250409017-02

Site: Collection Date/Time: 04/08/2025 05:29

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	04/13/25 19:53	

Sample ID: Summit Speech School - 705
Central Avenue. Mew
Providence NJ 07974 / RM 136

Lab Sample ID: 250409017-03

Site: Collection Date/Time: 04/08/2025 05:30

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	04/13/25 20:01	

Sample ID: Summit Speech School - 705
Central Avenue. Mew
Providence NJ 07974 / RM 128

Lab Sample ID: 250409017-04

Site: Collection Date/Time: 04/08/2025 05:35

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	0.00117 mg/l	0.015	0.00100	0.00055	20044	04/13/25 20:04	



Garden State Laboratories, Inc.

Sample ID: Summit Speech School - 705 Lab Sample ID: 250409017-05
 Central Avenue. Mew
 Providence NJ 07974 / RM 131

Site: Collection Date/Time: 04/08/2025 05:33

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	04/13/25 20:07	

Sample ID: Summit Speech School - 705 Lab Sample ID: 250409017-06
 Central Avenue. Mew
 Providence NJ 07974 / RM 151

Site: Collection Date/Time: 04/08/2025 05:37

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	04/13/25 20:10	

Sample ID: Summit Speech School - 705 Lab Sample ID: 250409017-07
 Central Avenue. Mew
 Providence NJ 07974 / RM 181

Site: Collection Date/Time: 04/08/2025 05:39

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	0.00135 mg/l	0.015	0.00100	0.00055	20044	04/13/25 20:12	

Sample ID: Summit Speech School - 705 Lab Sample ID: 250409017-08
 Central Avenue. Mew
 Providence NJ 07974 / RM 154

Site: Collection Date/Time: 04/08/2025 05:40

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	04/13/25 20:15	

Sample ID: Summit Speech School - 705 Lab Sample ID: 250409017-09
 Central Avenue. Mew
 Providence NJ 07974 / RM 106

Site: Collection Date/Time: 04/08/2025 05:42

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	0.00138 mg/l	0.015	0.00100	0.00055	20044	04/13/25 20:18	



Garden State Laboratories, Inc.

Sample ID: Summit Speech School - 705 Lab Sample ID: 250409017-10
 Central Avenue. Mew
 Providence NJ 07974 / RM 112

Site: Collection Date/Time: 04/08/2025 05:43

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	04/13/25 20:21	

Sample ID: Summit Speech School - 705 Lab Sample ID: 250409017-11
 Central Avenue. Mew
 Providence NJ 07974 / RM 114

Site: Collection Date/Time: 04/08/2025 05:45

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	04/13/25 20:24	

Sample ID: Summit Speech School - 705 Lab Sample ID: 250409017-12
 Central Avenue. Mew
 Providence NJ 07974 /Mens Rm

Site: Collection Date/Time: 04/08/2025 05:46

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	0.00252 mg/l	0.015	0.00100	0.00055	20044	04/13/25 20:27	

Sample ID: Summit Speech School - 705 Lab Sample ID: 250409017-13
 Central Avenue. Mew
 Providence NJ 07974 /Lady Rm

Site: Collection Date/Time: 04/08/2025 05:47

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	04/13/25 20:41	

Sample ID: Summit Speech School - 705 Lab Sample ID: 250409017-14
 Central Avenue. Mew
 Providence NJ 07974 / Locker Rm

Site: Collection Date/Time: 04/08/2025 05:48

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	04/13/25 20:44	



Garden State Laboratories, Inc.

Sample ID: Summit Speech School - 705
 Central Avenue. Mew
 Providence NJ 07974 / Staff
 Kitchen

Lab Sample ID: 250409017-15

Collection Date/Time: 04/08/2025 05:50

Site:
 Matrix: Potable water
 Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	04/13/25 20:47	

DF=Dilution factor, <=less than, MCL=Maximum Contaminant Level, Rep. Limit=Reporting Limit, MDL=Method Detection Limit, SM YR=Standard Methods Publication Year, and NC=Not Certified. The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice. Main Lab certified by NJDEP #20044-TNI, NY Dept. of Health #11550 and PADEP #68-03680.